



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED

VISAKHAPATNAM STEEL PLANT

RAW MATERIAL HANDLING PLANT

ELECTRICAL SHIFT REPORT

Date: 29/12/2025

Incharge(s): K SANKARA RAO

Shift: A

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	BRC ON CO-28	REPORTED B/W-1 NOT RUNNING FOUND GUIDE ROLLER AND CHAIN FELL DOWN	INFORMED TO MECHANICAL	07:45:00	08:00:00	
2	OHP	TBS ON CO-22	REPORTED LBC ,LT NOT WORKING FOUND LT M-2, M-4 OLR ACTED DUE TO TRACK JAMMING AND LBC MATERIAL JAMMING	RESET DONE AND MATERIAL CLEANED BY OPERATION	09:15:00	09:25:00	
3	OHP	CO-85	OLR ACTED	RESET DONE	11:55:00	12:00:00	
4	CHP	CC-18	REPORTED STOPPING ON ZSS FOUND ZSS CAGE STUCK UP WITH COAL PIC	REMOVED THAN OK	06:30:00	06:40:00	
5	CHP	CC-131	TRIPPED ON OLR (2times)	reset done	12:10:00 13:10:00	12:15:00 13:15:00	
6	CHP	CC-51A	OLR ACTED	RESET DONE	10:35:00	10:40:00	
7	CHP	CC-51	MPD ACTED FEEDING CONVEYOR	RESET DONE	10:50:00	10:55:00	
8	CHP	CC-40 SCR-2	REPORTED B/C STOPPING FREQUENTLY FOUND ZSS CAGE STUCK UP WITH COAL PIC	REMOVED THAN OK	07:35:00	07:45:00	
9	CHP	CC-33 SCR-3	REPORTED B/W FREQUENTLY STOPPED DUE TO ACCUMULATED PRESSURE PROBLEM	INFORMED TO MECHANICAL	11:30:00	11:45:00	