



वी.एस.पी  
VSP

# RASHTRIYA ISPAT NIGAM LIMITED

VISAKHAPATNAM STEEL PLANT

RAW MATERIAL HANDLING PLANT

ELECTRICAL SHIFT REPORT

Date: 14/01/2026

Incharge(s): Lal Singh,Lal Singh

Shift: B

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	wbr on co 26	slew drive tripped	reset done	15:00:00	15:10:00	
2	OHP	WBR ON CO 25	BC NOT RUNNING .. YARD ZSS CAGE STUCK	MADE FREE	16:05:00	16:15:00	
3	OHP	CO-33M	TRIPPED ON OLR	RESET DONE	18:25:00	18:30:00	
4	OHP	CO -7	CHUT SENSOR ACTED ... FUSE TB LOOSE	FIXED PROPERLY	19:15:00	19:25:00	
5	OHP	CO-6A WBR	BC NOT RUNNING ... CHUT SENSOR ROD WAS KEPT OUTSIDE	KEPT IN CHUT THEN HEALTHY	19:30:00	19:40:00	
6	CHP	CC-28	TRIPPED ON OLR	RESET DONE	15:00:00	15:05:00	
7	CHP	CC-51	MPD TRIPPED 6 TIMES	RESET DONE	16:00:00	21:00:00	
8	CHP	CC-51	TRIPPED ON OLR	RESET DONE	16:15:00 20:20:00	16:20:00 20:25:00	
9	CHP	CC-39 SCR-6	BC NOT RUNNING	FAULT RESET DONE AND TESTED	21:25:00	21:45:00	
10	WT	OT -4	DRIVE-1 TRIPPED ON PGF-4 FAULT	RESET DONE	20:40:00	20:45:00	