



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 03/02/2026

Shift: A

Incharge(s): K SANKARA RAO

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	CO-111	MPCB TRIP	MADE ON THAN OK	07:30:00	07:40:00	
2	OHP	BRC ON CO-28	REPORTED DRIVES ARE NOT RUNNING CHECKED AND FOUND MIDDLE PHASE HT FUSE BLOWN I/O PENAL DUE TO B PHASE LUG GOT CUT IN SLIP-RING BOX	LUG REPLACED AND SLIP-RINGS CLEANING WAS DONE HT FUSE REPLACED WITH NEW THAN OK	07:30:00	10:15:00	
3	OHP	CO-29	OLR ACTED (2TIMES)	RESET DONE	07:30:00 10:55:00	07:40:00 11:05:00	
4	OHP	BRC ON CO-32	B/W S NOT RUNNING OIL LOW LEVEL	INFORMED TO MECHANICAL	13:40:00	13:55:00	
5	CHP	CC-28	OLR ACTED	RESET DONE	10:35:00	10:40:00	
6	CHP	CC-131	OLR ACTED (2TIMES)	RESET DONE	11:45:00 13:05:00	11:50:00 13:10:00	
7	CHP	CC-51	MPD TRIP (8 TIMES) FEEDING CONVEYOR STOP	RESET DONE	08:30:00	09:45:00	
8	CHP	CC-43	OLR ACTED	RESET DONE	09:35:00	09:40:00	
9	CHP	CC-31 SCR-4	REPORTED B/W NOT RUNNING	POWER AND CONTROL RE-CYCLED THAN OK	12:55:00	13:10:00	
10	WT	OP-1	DRIVE-5 OLR ACTED (2TIMES) FOUND SPARK OBSERVED FROM MOTOR TB	COIL CONNECTION REMOVED AND RESET DONE THAN OK	11:00:00	11:35:00	
11	IOSA	LBDS-2 OM-4, OM-1	PLC COMMUNICATION PROBLEM (2 TIMES)	POWER RE- CYCLED	07:35:00 09:00:00	08:25:00 09:10:00	