



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 30/09/2025

Incharge(s): K SANKARA RAO

Shift: A

| Sl No | Area | Equipment | Problem | Action | From | To | Remarks |
|-------|------|--------------|---|---|----------|----------|---------|
| 1 | OHP | TBS ON CO-20 | RBC CONTROL MCB TRIP | RESET DONE | 06:30:00 | 06:40:00 | |
| 2 | OHP | CR-3 | REPORTED CR-3 NOT RUNNING CHECKED AND FOUND OIL FLOW NOT OK FAULT SHOW INFORMED TO MECHANICAL | OIL TOP UP THAN FAULT RESET DONE | 07:30:00 | 07:40:00 | |
| 3 | OHP | CO-35 | OLR ACTED | RESET DONE | 08:40:00 | 08:50:00 | |
| 4 | OHP | BRC ON CO-30 | LT NOT TAKING PLACE FOUND PCRD O/T ACTED | RELEASED | 12:15:00 | 12:25:00 | |
| 5 | OHP | CO 84 | REPORTED STOPPING ON PULL CHORD | PULL CHORD BYPASSED OPERATION REQUIREMENT | 12:50:00 | 13:00:00 | |
| 6 | OHP | RSCO-10A C/D | OLR ACTED | RESET DONE | 11:00:00 | 11:10:00 | |
| 7 | CHP | CC-51 | MPD TRIP (12TIMES) FEEDING CONVEYOR | RESET DONE | 08:00:00 | 12:00:00 | |
| 8 | CHP | CC-52 TIS | OLR ACTED | RESET DONE | 09:40:00 | 09:50:00 | |
| 9 | CHP | CC-37 SCR-7 | SLEW NOT WORKING FOUND OIL LEVEL LOW | INFORMED TO MECHANICAL | 07:15:00 | 07:25:00 | |
| 10 | CHP | CC-37 SCR-7 | LT NOT WORKING PCRD O/T ACTED | RELEASED THAN OK | 10:45:00 | 10:55:00 | |
| 11 | CHP | CC-33 SCR-5 | LT MOTER-2 MPCB TRIP | RESET DONE THAN LT OK | 09:45:00 | 09:55:00 | |
| 12 | CHP | CC-112 SCR-8 | SLEW NOT WORKING FOUND SLEW LIMIT ACTED | LIMIT RELEASED THAN OK | 11:20:00 | 12:30:00 | |



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 30/09/2025

Incharge(s): K SANKARA RAO

Shift: A

| Sl No | Area | Equipment | Problem | Action | From | To | Remarks |
|-------|------|----------------|------------------------------------|--------------------|----------|----------|---------|
| 13 | CHP | CC-33 SCR-5 | B/C NOT RUNNING FOUND MPD TRIP | RESET DONE THAN OK | 11:35:00 | 11:50:00 | |
| 14 | WT | OT-3 | NOT ROTATING DRIVE-1 ENCODER FAULT | RESET DONE | 06:30:00 | 06:50:00 | |