



वी.एस.पी  
VSP

**RASTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL GENERAL SHIFT REPORT**

Date: 23/06/2025

Area: CHP

Equipment	Job
Coal complex,LC 17	Rooms cleaning done
SCR 10	5 nos tube fixtures replaced in MCC room
SCR 4	PCRD rev command relay replaced and trial run was taken
SCR 1	Boom position sensor kept in ckt
CC 201 to 206	PPM was done