



वी.एस.पी  
VSP

**RASTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL GENERAL SHIFT REPORT**

Date: 22/05/2025

Area: OHP

Equipment	Job
co-6 pullchord	kept in circuit after rectifying switch contact issue.
lc-6, om-10, locp-2 crusher mcc	water levels and sump pumps working status is checked.
brc shifting	brc is shifted fro co-32 to co-30
co-2a, rsco-10a and its positions	bits are rearranged as per new io list.
rsco-10a	belt motor is replaced, tested directions and restored for operation. Both CJD's were not operating, informed instrumentation.