



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 05/10/2025

Shift: C

Incharge(s): Saurabh Kumar Yadav

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	CO 29	DMPR tripped due to overload	reset	22:20:00	22:25:00	
2	OHP	BRC on CO 33M	B/c not running,olr acted,due to jamming	reset,informed operation	23:50:00	00:05:00	
3	OHP	CO 77	olr acted	reset	04:30:00	04:35:00	
4	OHP	vs2	olr acted	reset	01:05:00	01:10:00	
5	CHP	CC 112 SCR 8	bc not running,belt offcentre,full jamming,zss acted	no electrical problem,fault reset done to unlatch zss fault,informed operation for cleaning	23:30:00	23:40:00	
6	CHP	CC 112 SCR 8	luff not working,oil level low	bit bypass luff down,than kept in ckt than all ok	23:20:00	23:40:00	to be checked in G shift
7	CHP	CC45	olr acted	reset	23:50:00	00:00:00	
8	CHP	CC 104 SCR 9	bc not running,mpr tripped	reset	01:25:00	01:35:00	
9	CHP	CC 33 scr 5	Lt not working,M3 mpcb tripped	made it on	03:30:00	03:45:00	
10	CHP	CC 38 SCR 6	LT not working,drive tripped	reset	04:37:00	04:45:00	
11	WT	OT 3	d1 tripped in encoder fault	reset	23:55:00	23:58:00	3 times
12	IOSA	old WOBR	b/c not running,olr acted due to jamming	olr reset,informed operation	22:35:00	22:45:00	
13	IOSA	L and T WOBR	b/w not running,oil level low	informed mechanical	00:10:00	00:25:00	