



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED

VISAKHAPATNAM STEEL PLANT

RAW MATERIAL HANDLING PLANT

ELECTRICAL GENERAL SHIFT REPORT

Date: 29/07/2025

Area: WT

| Equipment | Job |
|------------------|---|
| EOT Crane(O) | Control circuit checked,found OK bypass removed |
| OT 5 | Hooper area lighting,circuit problem rectified |
| OP 8 | panel and motor side ppm done |
| OP 2,3,4,6 and 7 | after rake maintenance done |