



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL GENERAL SHIFT REPORT**

Date: 18/10/2025

Area: CHP

Equipment	Job
CC-51 tunnel lighting	CC-111 flap gate point to CC-51 wall side, two 200w led lights arranged for cleaning work
VS-1,VF-1	motor and panel ppm done
STK-2	support for HT cable joint done by DNW.
SCR-1	control cables laying done from existing PLC panel to new PLC panel
SCR-1	Lower house MCC room roof sgeets welding work done and new PLC panel shifting to upper house and fixing of panel done.
CC-126 T/E lighting	120w led fixing done
CC-210,211,212	ppm work done
CC-204,205,206,207,208,209	ppm work done