



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 12/09/2025

Incharge(s): V Balaji Naik, Saurabh Kumar Yadav

Shift: C

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	CO 9	OLr acted	reset	22:45:00	23:55:00	
2	OHP	BRC on CO 34	zss interlock not working, cjd acted	CJD sensor adjusted	00:05:00	00:20:00	
3	OHP	BRC on CO 28	yard conveyor zss interlock not working, loose connection	tightened module TBs	03:15:00	03:35:00	
4	CHP	CC 28	olr acted	reset	01:00:00	01:05:00	
5	CHP	CC 51	mpd trips	reset it done	22:30:00	06:00:00	4 times
6	CHP	SCR 1 on CC 36	luffing not working, OLR acted	reset	23:37:00	23:50:00	
7	CHP	SCR1 on CC 36	CS acted due to rain	cleaning done bypassed and removed	02:00:00	02:10:00	
8	CHP	SCR4 on CC31	TUL bypassed as per operational request	bypassed and removed	00:59:00	01:05:00	