



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL GENERAL SHIFT REPORT

Date: 17/10/2025

Area: WT

Equipment	Job
OP 4	Panel and Motor side ppm done
OT 5 Lighting	Out haul side near Camera light connected in timer circuit
CT Bay lighting	CT 2 out haul side track focus light (400W S V) rectified and one 200W LED installed near CT 3 bay
MIS	CO 4 to CO 5 ,walkway bridge area 120W LED installed
MIS	R M D room @ Railway building, Supply problem,rectified
OP 4,5,2 and 8	After rake, maintenance done