



वी.एस.पी  
VSP

# RASHTRIYA ISPAT NIGAM LIMITED

VISAKHAPATNAM STEEL PLANT

RAW MATERIAL HANDLING PLANT

ELECTRICAL GENERAL SHIFT REPORT

Date: 21/08/2025

Area: WT

Equipment	Job
OT 3 and 4	area lighting R-phase fuse base replaced in LC 1
OT 5 series	Running inspection done
CP 3	D2 burnt motor shifted to ore tippler complex,and coupling removed
OP 1	D6 cable R-phase got cut,made it joint ,D4 slip ring buffing done and 2 nos brushes replaced
OP 1,4 and 10	After rake maintenance done ,top C-clamp replaced in OP 10