



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 23/12/2025

Shift: B

Incharge(s): Saurabh Kumar Yadav

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	CO 26	olr acted	reset	16:00:00 17:10:00	16:05:00 17:20:00	2 times
2	OHP	WOBR on co 26	bc not running, material jamming	informed operation	17:40:00	17:55:00	
3	OHP	TT1 on co 8A	position wire got cut	rejointed	17:30:00	17:45:00	
4	CHP	CC 34 SCR1	luff not working, up limit acted	limit released	19:20:00	19:35:00	
5	CHP	CC 31 SCR4	BC zss probe	replaced and kept in ckt	14:20:00	14:40:00	
6	CHP	CC 51 A	motor tripped in olr	reset	14:45:00	14:50:00	
7	CHP	CC 51	MPD tripped 5 times	reset	17:30:00	20:30:00	
8	CHP	CC 52	mpd tripped 2 times	reset	19:10:00	20:00:00	
9	CHP	CC 102 T/car	chute sensor fbk supply wire loose contact	properly connected	14:40:00	15:00:00	