



वी.एस.पी
VSP

RASTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 29/05/2025

Incharge(s): Lal Singh

Shift: B

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	CO-29	TRIPPED ON OLR	RESET DONE	17:55:00 18:40:00	18:05:00 18:50:00	
2	OHP	CC-34	ZSS PROB WIRE CUT	JOINT DONE	19:30:00	19:50:00	
3	OHP	CO-19 TBS	L-LUFF NOT WORKING	BREAKS TO BE ADJUSTED ... INFORMED MECH	21:10:00	21:30:00	
4	OHP	CO-28 BRC	BW NOT ROTATING	CHAIN FALLEN .. INFORMED OPR	21:20:00	21:40:00	
5	OHP	CO4A	BRS BYPASS REQ	BYPASSED IN CJB	14:40:00	14:50:00	
6	CHP	CC-36 SCR-1	LUFF NOT WORKING	CONTROL MCB OFF.... MADE ON	17:20:00	17:35:00	
7	CHP	ALL MACHINE	COMMUNICATION PROBLEM	ANTENNA CLEANED AND CHECKED	19:15:00	20:00:00	
8	CHP	CC-131	TRIPPED ON OLR	RESET DONE	16:50:00 18:00:00	16:55:00 18:05:00	
9	CHP	CC-54	TRIPPED ON OLR	RESET DONE	17:45:00 18:15:00 18:45:00	17:50:00 18:25:00 18:50:00	
10	CHP	CC-52	OHP SIDE MOTOR KEPT IN LINE ..	DUE TO MECH PROBLEM	14:00:00	16:00:00	
11	CHP	CC-39	TRIPPED ON OLR	RESET DONE	19:00:00	19:10:00	