



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 16/07/2025

Incharge(s): K SANKARA RAO

Shift: C

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	BRC ON CO 32	LT NOT TAKING PLACE PCRD O/T ACTED	RELEASED	00:30:00	00:45:00	
2	OHP	CO 35	OLR ACTED	RESET	00:30:00	00:40:00	
3	OHP	WOBR ON CO 25	B/W OLR ACTED	RESET	01:00:00	01:40:00	
4	OHP	CO 26	OLR ACTED	RESET	01:40:00	01:50:00	
5	OHP	BRC ON CO 34	B/C NOT RUNNING CONTROL MCB TRIP	MADE ON	02:45:00	03:00:00	
6	OHP	WOBR ON CO 6A	B/C BSS ACTED DUE TO BELT OFF CENTERING AND THROUGH CUT	IN FORMED TO OPERATION AND BSS RESET	03:00:00	03:15:00	
7	OHP	BF 8A	STOPPING ON ZS	PROBE ADJUSTED THAN OK	23:40:00	00:00:00	
8	CHP	CC 19	OLR ACTED	RESET	02:10:00	02:15:00	
9	CHP	CC 09	OLR ACTED	RESET	02:45:00	02:55:00	
10	CHP	CC 54	OLR ACTED(2TIMES)	RESET	22:00:00	22:10:00	
11	CHP	CC 51	STOPPING ON ZS MECH PROBLEM	IN FORMED TO OPERATION	01:00:00	01:15:00	
12	CHP	CC 51A	OLR ACTED(2TEMES)	RESET	04:25:00	04:40:00	
13	CHP	CC 113	STOPPING ON ZS DUE TO BELT SNAP	IN FORMED TO MECH	04:15:00	04:20:00	
14	CHP	CC 35 SCR 1	LT NOT TAKING PLACE DRIVE TRIP(OVN)	RESET	00:30:00	00:45:00	
15	CHP	CC40 SCR 6	B/C NOT RUNNING SIGNAL MISSING	LT FWD MOVE THAN OK	02:00:00	02:10:00	



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 16/07/2025

Incharge(s): K SANKARA RAO

Shift: C

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
16	CHP	CC 35 SCR 1	LUFFING UP NOT TAKING PLACE OLR ACTED	RESET	03:20:00	03:30:00	
17	CHP	CC 112 SCR 8	LT NOT TAKING PLACE	WRONG COMPLAINT	03:35:00	03:40:00	
18	WT	OP 2	D 5 TRIP	RESET	02:45:00	03:00:00	