



वी.एस.पी  
VSP

# RASHTRIYA ISPAT NIGAM LIMITED

VISAKHAPATNAM STEEL PLANT

RAW MATERIAL HANDLING PLANT

ELECTRICAL SHIFT REPORT

Date: 12/09/2025

Shift: A

Incharge(s): Nagendra Midde

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	CO 15	OLR ACTED	RESET	06:40:00 07:35:00	06:45:00 07:45:00	
2	OHP	CO 7A	LEFT BOOM DRIVE TRIPPED	MADE IT ON	09:15:00	09:30:00	
3	OHP	CO 28	YARD INTERLOCK ZSS PROBR DAMAGED	REPLACED	11:30:00	11:50:00	
4	OHP	CO 111	MPCB TRIP	MADE IT ON	10:45:00	10:55:00	
5	OHP	RSCO 6A	OLR ACTED	RESET	13:20:00	13:30:00	
6	OHP	VS2 A	C/S	KEPT IN CIRCUIT	12:00:00	12:30:00	
7	CHP	CC 22 FWD NOT RUNNING	COIL CONNECTION LOOSE	TIGHTENED	09:00:00	09:15:00	
8	CHP	SCR 7 ON CC 37 COOLING FAN	CABLE FAULT	OUT GOING CONNECTIONS REMOVED	07:00:00	07:30:00	NEW CABLE LAYING UNDER PR OGRESS
9	CHP	SCR 7 ON CC 37	B/C OLR ACTED DUE TO BELT THROUGH CUT	RESET	07:00:00	07:30:00	
10	CHP	CC 53 T/T	OLR ACTED	RESET	08:00:00	08:20:00	
11	CHP	CC 54	OLR ACTED	RESET	13:30:00	13:35:00	