



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED

VISAKHAPATNAM STEEL PLANT

RAW MATERIAL HANDLING PLANT

ELECTRICAL SHIFT REPORT

Date: 29/09/2025

Shift: B

Incharge(s): Amit Roy

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	TBS on CO-21	Reported LT not taking place	Checked and found control off. control made on and tested okay	16:00:00	16:10:00	
2	OHP	BRC on CO-30	Reported LT not taking place	Checked and found skew limit acted. Skew adjusted and tested okay	16:30:00	16:45:00	
3	OHP	CO-35	Reported tripped	OLR acted. Reset done	19:10:00	19:20:00	
4	OHP	TBS on CO-5A	Reported LT not taking place	PCRD tension acted. PCRD tension released and tested okay	20:10:00	20:25:00	
5	OHP	BRC on CO-30	Reported B/W-1 not rotating	Checked and found cable and fuse problem. Rectified and tested okay	18:20:00	18:45:00	Fuse TB to be replaced at XMD panel
6	OHP	CO-34A	Reported fault acted in siprotec relay 46-TOC	Checked and found motor burnt.	17:10:00	17:25:00	Motor replacement is going on
7	OHP	CO-28,29,20,26	Reported no power in machines	Checked and found two fuses burnt in CO-20 IO. I/C made on in LBDS and given clearance for other machines	17:40:00	18:00:00	HT cable checking is going on for TBS on CO-20
8	CHP	CC-37 SCR-7	Reported LT not taking place	PCRD overtension acted. Released and tested okay	16:10:00 16:50:00	16:25:00 17:00:00	
9	CHP	CC-38 SCR-6	Reported B/C not running	OLR acted. Reset done	20:30:00	20:45:00	
10	CHP	CC-58	Reported tripped	OLR acted, Reset done	16:15:00	16:30:00	



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 29/09/2025

Incharge(s): Amit Roy

Shift: B

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
11	CHP	CC-25	Mechanical BRS damaged	Replaced and tested okay	15:00:00	16:00:00	
12	WT	OP-3	Reported not moving.	Tippler initial not coming.Hopper jamming found.	14:45:00	14:50:00	Informed to operation
13	WT	OP-3	Not reached deadend	Wrong complaint	21:45:00	22:00:00	
14	IOSA	TBS ON OC-13A	Reported not moving	End limit acted due to grass.Bypassed as per operation request	21:30:00	22:00:00	