



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL GENERAL SHIFT REPORT**

Date: 13/11/2025

Area: OHP

| Equipment  | Job   |
|--|---|
| tbs- on repair bay                               | rbc motor termination is done and zss cable is laid.,   |
| brc 5 on co-32                                   | festoon cable cleaned and maintenance is done ; bridge conveyor motor earth jumper is provided. |
| tbs-2 on oc-22                                   | pcrd resistance box cleaned;  |
| co-86 head end ; 77,78 gallery                   | illumination is improved  |
| co-77,84,86 and their hoists                     | motor and panel side ppm is done  |
| co-13a, 42a ,14b,16a ,11a,vs-1a level gallery, ; | illumination is improved  |
| daybins-2 ; 11a,12a, cbms- on co-11a hoists      | hoists ppm is done  |
| reclaiming streams                               | cjd's ppm is done   |