



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 06/07/2025

Shift: B

Incharge(s): K SANKARA RAO

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	RSCO 9A BELT DRIVE	OLR ACTED	RESET	14:00:00	14:10:00	
2	OHP	TBS ONCO 21	L/LUFF OLR ACTED	RESET	14:10:00	14:20:00	
3	OHP	TBS ON CO 20	PCRD CHAIN PROBLEM	AFTER CHANG THE CHAIN PCRD CABLE LAYERING WITH MECHANICAL	14:20:00	14:50:00	
4	OHP	TBS ON CO 20	L/LUFF NOT TAKING PLACE LIMIT TIEGHED WITH ROPE	LIMIT RELEASED THAN OK	15:00:00	15:10:00	
5	OHP	TBSON CO 20	LT NOT TAKING PLACE E/STOP ACTED DUO TO MAIN CONTROL TRIP	MAIN CONTROL ON THAN OK	19:00:00	19:20:00	
6	OHP	TBS ON CO 20	L/LUFF NOT TAKING PLACE DRIVE TRIP ON GROUND FAULT DUE TO BRAKE PROBLEM	BRAKE ADJUSTED WITH MECH HELP	21:10:00	22:30:00	
7	OHP	CO 26	OLR ACTED (2TIMES)	RESET	21:20:00	21:40:00	
8	CHP	CC 45	OLR ACTED	RESET	15:55:00	16:10:00	
9	CHP	CC 105 SCR 10	SIGNAL NOT SHOWING IN CCR	RECLAIMING SIGNAL REMOVED IN CM 18 THAN OK	16:05:00	16:20:00	
10	CHP	CC 105 SCR 10	SIGNAL MISSING	LT MOVED REVERSE DIRECTION THAN OK	18:00:00	18:10:00	
11	CHP	CC 32 SCR 5	LT NOT TAKING PLACE MPCB 2 TRIP	RESET	16:35:00	16:45:00	
12	CHP	CC 48	ZS PROBLEM CHECKED PULLEY OUT PUT COUPLING PROBLEM	INFORMED TO MECH	16:35:00	16:50:00	



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 06/07/2025

Incharge(s): K SANKARA RAO

Shift: B

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
13	CHP	CC 38 SCR 3	ZS PROBE AND ZS CAGE STUCK	ZS PROBE CHANGED AND ZS BYPASSED	18:50:00	19:30:00	
14	CHP	CC 38 SCR 3	B/C STOPPING SIGNAL PROBLEM	POSITION CHANGED GVM TO CCR THAN OK	19:30:00	20:10:00	
15	CHP	CC 31 R 1	LUFFING NOT TAKING PLACE MATERIAL JAMMING	INFORMED TO OPERATION	20:10:00	20:25:00	
16	CHP	CC 125	OLR ACTED	RESET	21:10:00	21:15:00	
17	CHP	CC 35	BRS PROBLEM	BY PASSED	18:30:00	18:45:00	
18	CHP	CC 104 SCR 9	SLEWING NOT TAKING PLACE MCCB Y PHASE PROBLEM	MCCB BY PASS WITH JUMPER	18:30:00	20:30:00	
19	CHP	CC 51A	OLR TRIP	RESET	20:05:00	20:25:00	DUE TO JAMMING
20	CHP	CC 52(DOL)	OLR ACTED	RESET	17:15:00	17:20:00	
21	CHP	CC 53	OLR ACTED	RESET	17:40:00	17:45:00	
22	CHP	CC 131	OLR ACTED	RESET	21:05:00	21:10:00	
23	WT	CP 3	D1 OLR ACTED (2TIMES)	RESET AND DOS POT OIL CHANGED THAN OK	14:30:00	15:00:00	