



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL GENERAL SHIFT REPORT

Date: 01/12/2025

Area: WT

Equipment	Job
OP 1	D 4 motor slip rings buffing and cleaning done and brush holder repaired
OP 1	D 4 motor, fixed the brush holder and replaced all brushes, kept in circuit
OP 6 and CP 1	After rake, maintenance done