



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 01/08/2025

Shift: B

Incharge(s): Lal Singh, Arnab Roy

| Sl No | Area | Equipment | Problem | Action | From | To | Remarks |
|-------|------|----------------|---------------------------------------|---|----------|----------|---------|
| 1 | OHP | BRC on CO 28 | BC not running | OLR acted | 16:50:00 | 17:00:00 | |
| 2 | OHP | TBS on CO 22 | Main braker tripped due to E PB acted | E PB released and braker made on | 18:15:00 | 18:30:00 | |
| 3 | OHP | WOBR on CO 26 | LT limit acted . Also no control | LT limit bypassed and again kept in circuit. Control fuse 32A blown , loop given . Then healthy | 20:00:00 | 21:00:00 | |
| 4 | OHP | CO 26 | OLR acted | reset done | 21:10:00 | 21:20:00 | |
| 5 | CHP | CC 34 , SCR 2 | Luff not working | wrong complaint | 15:30:00 | 15:40:00 | |
| 6 | CHP | CC 105 SCR 7 | Slew not working | charge pressure alarm , spider reset | 17:10:00 | 17:25:00 | |
| 7 | CHP | CC 105, SCR 7 | LT not working | ot ACTED , RELEASED | 21:05:00 | 21:10:00 | |
| 8 | CHP | cc 32, scr 5 | BC not running | OLR acted , reset done | 20:10:00 | 20:20:00 | |
| 9 | CHP | CC 34 | Yard conveyor overload acted | reset done | 20:55:00 | 21:05:00 | |
| 10 | CHP | CC 112 , SCR 8 | BW slew not working | oil level low. informed to mechanical | 21:25:00 | 21:35:00 | |
| 11 | CHP | CC 105, SCR 7 | BC signal missing | LT done , then ok | 21:10:00 | 21:25:00 | |
| 12 | CHP | CC 51 | OLR acted (5 times) | reset done | 18:40:00 | 21:10:00 | |
| 13 | CHP | CC 114 | OLR acted | reset done | 17:10:00 | 17:20:00 | |



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 01/08/2025

Incharge(s): Lal Singh, Arnab Roy

Shift: B

| Sl No | Area | Equipment | Problem | Action | From | To | Remarks |
|-------|------|-----------------|--|---|----------------------|----------------------|---------|
| 14 | CHP | CC 54 | OLR acted | reset done | 16:00:00 | 16:15:00 | |
| 15 | WT | CT 1 | Not rotating | CAM switch not healthy , cleaning then okay | 18:00:00 | 18:15:00 | |
| 16 | WT | OC 1A | Not healthy showing On feedback in Red | OLR acted in panel , reset done | 19:00:00 | 19:15:00 | |
| 17 | IOSA | OC 37A | OLR acted | reset done | 14:55:00 16:30:00 | 15:15:00 16:50:00 | |
| 18 | IOSA | L and T WOBR | LT not working due to pcrd overtension acted | released, then okay | 20:50:00 | 21:00:00 | |