



वी.एस.पी
VSP

RASTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL GENERAL SHIFT REPORT

Date: 06/05/2025

Area: OHP

Equipment	Job
BRC on CO-8A	Conveyor ZSS module installation done
TBS on CO-5A,BRC on CO-32	LT brake rectification done
CO-32	Conveyor and hoist PPM done
BRC-2 ON CO-32	PPM done
rsco-9a	h/e area illumination is improved.
co-4a brs	checked, sensors got loose, realigned and tightened in position and restored in circuit.
co-12a removed motor	sent to CME
co-50 spare motor	spare motor coupling is fixed and shifted to head end area.
co-57	tail end p/c switches cable is laid and restored in circuit.