



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED

VISAKHAPATNAM STEEL PLANT

RAW MATERIAL HANDLING PLANT

ELECTRICAL SHIFT REPORT

Date: 07/10/2025

Shift: B

Incharge(s): Nagendra Midde

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	DB1	OLR ACTED	RESET	15:05:00	15:15:00	
2	OHP	CO 26	OLR ACTED	RESET	20:20:00 21:35:00	20:30:00 21:45:00	
3	OHP	CO 11 CD	OLR ACTED	RESET	15:45:00	16:00:00	
4	CHP	SCR 2 ON CC 34	30 DEGREE LIMIT ACTED	RESET	18:55:00	19:10:00	
5	CHP	SCR 7 ON CC 37	BREAK FAIL ALARM ACTED	RESET	21:00:00	21:15:00	
6	CHP	CC 125	OLR ACTED	RESET	15:45:00	15:50:00	
7	CHP	CC 102	BRS ACTING FREQUENTLY DUE TO LOOSE CONNECTION IN MODULE	TIGHTENED THEN OK	20:45:00	21:00:00	
8	CHP	CC 51	FEEDING CONVEYOR MPD ACTED	RESET	15:00:00	22:00:00	5 TIMES
9	WT	OT1	PGF1 DRIVE FAULT	RESET	19:30:00	19:35:00	
10	WT	CP1 NOT MOVING	MAIN CONTACTOR OFF	MADE IT ON	19:15:00	19:20:00	
11	WT	OT4	INITIAL INDICATION NOT COMING	SENSOR CLEANED THEN OK	20:30:00	20:35:00	
12	IOSA	WBR L and T B/C	DOWN CJD SENSOR PROBLEM	BYPASSED AND INFORMED TO INSTRUMENTATION	17:50:00	18:05:00	