



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 20/11/2025

Shift: B

Incharge(s): sagar

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	wobr on co 25	slew not taking place,drive tripped	reset	16:00:00	16:10:00	
2	OHP	co 25	olr acted 2 times	reset	16:30:00	16:35:00	
3	OHP	TBS on co 7A	LT not taking place,reclaiming height not there	kept in reclaiming height	19:00:00	19:15:00	
4	OHP	WOBR on CO 25	LT not working in drive mode,drive tripped	drive reset,kept in VFD mode	20:30:00	20:45:00	operator kept in DOL mode,no one given complaint
5	OHP	VF 1A	motor mpcb tripped	reset	21:15:00	21:20:00	
6	CHP	CC 37 SCR 7	slew not working,break fail alarm	reset	15:15:00	15:25:00	
7	CHP	CC 38 SCR6	Lt not working,M2 mpcb tripped	reset	16:35:00	16:50:00	
8	CHP	CC 35 SCR3	LT not working,R3 relay NC contact problem	NC bypass	18:30:00	18:50:00	informed to G shift
9	CHP	CC 54	motor tripped 7 times in OL	reset	15:51:00	18:58:00	
10	CHP	CC 51	MPD tripped	reset	19:30:00	19:35:00	
11	WT	OT 2	d1 tripped in pgf4 fault	encoder replaced d2	15:30:00	16:00:00	operation cleaned roller of tippler