



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 03/11/2025

Shift: A

Incharge(s): Lal Singh,K SANKARA RAO

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	CO-26	TRIPPED ON OLR	RESET DONE	13:15:00	13:25:00	
2	OHP	BRC-32	LT SKEW ACTED	ADJUSTED WITH MECH	13:10:00	13:30:00	
3	OHP	BRC-33M	LT NOT WORKING .. PCRD GUIDE PROBLEM	ADJUSTED BY MECH	08:10:00	08:40:00	
4	OHP	LC-3 OM-29	IC-2 TRIPPED AND OM-29 TRIPPED	MADE ON AND TT-4 POWER MADE OFF	08:45:00 09:45:00	09:00:00 10:00:00	
5	OHP	TT-4	TRIPPING DUE TO CABLE FAULT IN JOINT AND SLIP RING	RECTIFIED	09:00:00	14:00:00	
6	CHP	CC-54	TRIPPED ON OLR (10TIMES)	RESET DONE	07:30:00	13:15:00	
7	CHP	CC-51	TRIPPED ON MPD (4TIMES) DUE TO FEEDING CONVEYOR STOP	RESET DONE	07:50:00	08:30:00	
8	CHP	CC-114	TRIPPED ON OLR	RESET DONE	13:15:00	13:20:00	
9	CHP	CC-114	REPORTED STOPPING ON ZSS CHECKED AND FOUND BELT SNAP	INFORMED TO OPERATION	13:25:00	13:30:00	
10	CHP	CC-43	TRIPPED ON OLR	RESET DONE	09:25:00	09:30:00	
11	CHP	CC-34 SCR-2	B/C NOT RUNNING C/S ACTED DUE TO MATERIAL JAMMING	AFTER CLEAR THE MATERIAL C/S THAN OK	08:45:00	09:00:00	
12	CHP	CC-34 SCR-2	LT NOT WORKING DRIVER TRIPPED	RESET DONE	10:15:00	10:25:00	
13	CHP	CC-33 SCR-5	BC NOT RUNNING MCCB TRIPPED	MADE ON AND TESTED	11:20:00	11:30:00	
14	CHP	CC-104 SCR-9	LUFF NOT WORKING MPCB TRIPPED	MADE ON	10:35:00	10:45:00	



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 03/11/2025

Incharge(s): Lal Singh, K SANKARA RAO

Shift: A

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
15	CHP	CC-44	TRIPPED ON OLR	RESET DONE	09:30:00	09:40:00	
16	WT	OT-2	DRIVE -1 TRIP PGF-4 FAULT (2TIMES)	RESET DONE	06:10:00	06:25:00	
17	WT	OT-1	NOT MOVE FOUND DRIVE-1 TRIP PGF-1 FAULT	RESET DONE	06:35:00	06:45:00	