



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL GENERAL SHIFT REPORT**

Date: 17/02/2026

Area: IOSA

Equipment	Job
OC-33A	PPM DONE ON MOTOR AND FIELD DEVICES.
1-28 HVMCC-6	MAINTENANCE DONE ON PANEL-3 HT BREAKER( FEEDING TO GROUND ISOLATOR-1). CHECKED IN TEST POSITION AND NORMALIZED.
GROUND ISOLATOR-1	MAINTENANCE DONE ON INCOMER AND OUTGOING TO OC-15A ( BLENDER). CLOSING AND TRIPPING FUNCTION CHECKED.
BLENDER RECLAIMER	LIGHTING DEFECTS RECTIFIED AND ARRANGED LIGHTING NEAR BUCKET WHEEL-1 AREA AND OC-15A CONVEYOR FOCUSING.
TBS	ALL MOTORS EARTHING CHECKED AND ARRANGED.
MANUAL UN-LOADING YARD	LIGHTING DEFECTS RECTIFIED AND 200W TWO LED LAMPS REPLACED IN POLE-4.