



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL GENERAL SHIFT REPORT**

Date: 14/01/2026

Area: CHP

Equipment	Job
CC 114 BRS	Relocation work under progress
CCR to CM 9	One line Prophibus cable laying completed
LC 17,18,CM 19	IO rack panel door openings closed with metal sheet
CC 45/46 tunnel	4 nos 30W LED fixtures provided
LBDS 4 and 5	Panels and floor cleaning done
CC 44,102,113,113A,125	PPM was done