



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL GENERAL SHIFT REPORT

Date: 20/12/2025

Area: WT

Equipment	Job
OP 10	Panel side ppm done
OP 10	D3 ,B phase O/G lug replaced and direct termination done@ drive module
OP 8	Panel and Motor side ppm done
CP 2 and 3	After rake, maintenance done
OP 2,3,4 and 6	After rake, maintenance done
MIS	M S sheets (3.15), primary painting done both sides 13 nos