



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 03/10/2025

Incharge(s): Nagendra Midde

Shift: B

| Sl No | Area | Equipment     | Problem                              | Action               | From                             | To                               | Remarks |
|-------|------|---------------|--------------------------------------|----------------------|----------------------------------|----------------------------------|---------|
| 1     | OHP  | CO 15         | OLR ACTED                            | RESET                | 15:45:00<br>16:00:00<br>21:45:00 | 15:50:00<br>16:05:00<br>21:55:00 |         |
| 2     | OHP  | BRC ON CO 28  | EMERGENCY PB ACTED IN OPERATOR CABIN | RELEASED             | 15:50:00                         | 16:05:00                         |         |
| 3     | OHP  | CO 33M LT     | PCRD CABLE LOOP GIVEN                | THEN OK              | 16:05:00                         | 16:20:00                         |         |
| 4     | OHP  | BRC ON CO 33M | INTERLOCK CAGE GETTING STUCK         | REPLACED THEN OK     | 16:40:00                         | 17:00:00                         |         |
| 5     | CHP  | S1 ON CC 39   | 30 DEGREE LIMIT ACTED                | RELEASED WITH MAGNET | 15:50:00                         | 16:00:00                         |         |
| 6     | CHP  | CC 39         | OLR ACTED                            | RESET                | 19:00:00                         | 19:05:00                         |         |
| 7     | CHP  | CC 32 R1      | SLEW LIMIT ACTED                     | RELEASED             | 20:30:00                         | 20:40:00                         |         |
| 8     | CHP  | CC 51         | FEEDING CONVEYOR OLR ACTED           | RESET                | 17:30:00                         | 17:35:00                         |         |
| 9     | WT   | OT3           | D1 TRIPPED ON ENCODER FAULT          | RESET                | 16:00:00                         | 16:05:00                         |         |
| 10    | WT   | CO3           | OLR ACTED                            | RESET                | 19:55:00                         | 20:00:00                         |         |
| 11    | IOSA | OC36A         | ZSS CAGE STUCK WITH STONE            | REMOVED THEN OK      | 17:30:00                         | 17:45:00                         |         |