



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 06/07/2025

Shift: B

Incharge(s): K SANKARA RAO

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	CHP	CC 45	OLR ACTED	RESET	15:55:00	16:10:00	
2	CHP	CC 105 SCR 10	SIGNAL NOT SHOWING IN CCR	RECLAIMING SIGNAL REMOVED IN CM 18 THAN OK	16:05:00	16:20:00	
3	CHP	CC 105 SCR 10	SIGNAL MISSING	LT MOVED REVERSE DIRECTION THAN OK	18:00:00	18:10:00	
4	CHP	CC 32 SCR 5	LT NOT TAKING PLACE MPCB 2 TRIP	RESET	16:35:00	16:45:00	
5	CHP	CC 48	ZS PROBLEM CHECKED PULLEY OUT PUT COUPLING PROBLEM	INFORMED TO MECH	16:35:00	16:50:00	
6	CHP	CC 38 SCR 3	ZS PROBE AND ZS CAGE STUCK	ZS PROBE CHANGED AND ZS BYPASSED	18:50:00	19:30:00	
7	CHP	CC 38 SCR 3	B/C STOPPING SIGNAL PROBLEM	POSITION CHANGED GVM TO CCR THAN OK	19:30:00	20:10:00	
8	CHP	CC 31 R 1	LUFFING NOT TAKING PLACE MATERIAL JAMMING	INFORMED TO OPERATION	20:10:00	20:25:00	
9	CHP	CC 125	OLR ACTED	RESET	21:10:00	21:15:00	
10	CHP	CC 35	BRS PROBLEM	BY PASSED	18:30:00	18:45:00	