



वी.एस.पी
VSP

RASTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL GENERAL SHIFT REPORT

Date: 20/05/2025

Area: OHP

| Equipment | Job |
|----------------|--|
| TIS-6 ON CO-29 | bypassed feedbacks at io rack and zss at module as conveyor belt was slipping. |