



वी.एस.पी
VSP

RASTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL GENERAL SHIFT REPORT

Date: 14/05/2025

Area: IOSA

Equipment	Job
OC-27A	LIGHTING DEFECTS RECTIFIED AT HEADEND
BRC	BRIDGE CONVEYOR BRAKE PANEL NOT WORKING, GOT RUSTED AND DAMAGED. REMOVED AND SHIFTED TO SHED FOR RECTIFICATION
OC-5A	MOTOR PPM DONE.
OC-37A	LIGHTING DEFECTS RECTIFIED AND LIGHTING ARRANGED.
BRC	POWER CABLE DRESSING DONE.