



वी.एस.पी  
VSP

**RASTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 02/05/2025

Incharge(s): V Balaji Naik,G Eswara Rao

Shift: A

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	tbs on co 20	It &right; luffing not taking place/	reclaiming height limit tied and luffing brake stuck ,released by hammer ing done	07:10:00	07:30:00	
2	OHP	brc on co31	bw 2 not running/olr acted	reset done	07:15:00	07:25:00	