



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED

VISAKHAPATNAM STEEL PLANT

RAW MATERIAL HANDLING PLANT

ELECTRICAL GENERAL SHIFT REPORT

Date: 17/11/2025

Area: IOSA

Equipment	Job
LIGHTING	LIGHTING TRANSFORMER AT OJH-12A OUTGOING TO SLDB CHECKED AND PROBLEM RECTIFIED.
BLENDER RECLAIMER	HT TRANSFORMER BASE FIXING BOLTS GOT RUSTED AND SHEARED. REPLACED AND TIGHTENED.
OC-29A	LIGHTING DEFECTS RECTIFIED AND SUFFICIENT LIGHTING ARRANGED.
OTT-1A	PPM DONE ON MOTOR AND FIELD DEVICES.