



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL GENERAL SHIFT REPORT

Date: 31/07/2025

Area: WT

Equipment	Job
OP 2	All drives de clutched and tested,control circuit checked,D2 O/L relay replaced
OP 6	Motor side ppm done
OP 5	After rake maintenance done
MIS	7 nos Pusher C- clamps assembling done/ made ready