



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED

VISAKHAPATNAM STEEL PLANT

RAW MATERIAL HANDLING PLANT

ELECTRICAL SHIFT REPORT

Date: 05/08/2025

Incharge(s): Lal Singh

Shift: A

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	CO-35	OVER LOAD ACTED	RESET DONE	08:35:00	08:40:00	
2	OHP	CO-34 BRC	NO DRIVES WORKING	ACB TRIPPED... MADE ON	09:45:00	10:00:00	
3	OHP	CO-6A WBR	LT NOT WORKING	MAIN IS IN OFF CONDITION MADE ON	11:55:00	12:10:00	
4	OHP	CO-26 WOBR	SLEW NOT WORKING	DRIVE TRIPPED RESET DONE	12:20:00	12:40:00	
5	OHP	CO-31 BRC	CHUT SENSOR ACTING BYPASS REQ FROM OPERATION	BYPASSED IT IS ACTING BECOUSE OF MATERIAL TOUCHING TO PROB	10:50:00	11:10:00	
6	OHP	CO-15	PULL CORD KEPT IN CKT	DONE	12:00:00	12:10:00	
7	CHP	cc-105 scr-7	HT CABLE PROBLEM	OLD JOINT FAILED... ISOLATOR MADE OFF .. INFORMED TO G SHIFT	06:15:00	06:30:00	
8	CHP	CC-38 S-1	PCRD GEARBOX PROBLEM	DRUM ARRESTED AND INFORMED TO MECH AND OPERATION	12:45:00	13:15:00	
9	CHP	CC-27A TT	TT POSITION ON CC-39 NOT COMING	SENSOR CLEANING DONE THEN OK	07:30:00	07:35:00	
10	CHP	CC-114	TRIPPED ON OLR	RESET DONE	13:40:00	13:45:00	