



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 18/11/2025

Incharge(s): Nagendra Midde

Shift: C

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	BRC ON CO 32 SLEW	24 V COMMON HIGH LOOSE IN CJB2	TIGHTENED	23:30:00	00:00:00	
2	OHP	WBR ON CO 26	SLEW DRIVE TRIPPED	RESET	02:45:00	03:00:00	
3	OHP	TBS ON CO 22	LT PCRD GOT STUCKED	AFTER MECH CLEARENCE PLACEMENT DONE	00:30:00	00:50:00	
4	OHP	CO 26	OLR ACTED	RESET	01:45:00 03:05:00	01:55:00 03:15:00	
5	OHP	WBR ON CO 29	B/W MPCB TRIPPED	MADE IT ON	02:20:00	02:40:00	
6	OHP	WBR ON CO 26 LT	MCCB OFF	MADE IT ON	00:40:00	00:55:00	
7	CHP	R1 ON CC 32	B/W OLR ACTED	RESET	22:50:00	23:05:00	
8	CHP	SCR 7 ON CC 37 LT	DRIVE FAULT	RESET	00:30:00	00:50:00	
9	CHP	CC 125	OLR ACTED	RESET	04:55:00	05:00:00	
10	CHP	CC 54	OLR ACTED	RESET	23:30:00	04:25:00	13 TIMES
11	CHP	CC 51	FEEDING CONV MPD ACTED	RESET	04:45:00	04:55:00	
12	CHP	CC 117	OLR ACTED	RESET	03:25:00	03:45:00	
13	CHP	SCR 5 ON CC 33	LT DRIVE TRIPPED	MADE IT ON	05:45:00	05:55:00	



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 18/11/2025

Incharge(s): Nagendra Midde

Shift: C

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
14	WT	CO 3	OLR ACTED DUE TO JAMMING	RESET	03:10:00	03:30:00	
15	WT	AF2	DRIVE TRIPPED ON OVERLOAD	RESET	01:05:00	01:10:00	