



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL GENERAL SHIFT REPORT

Date: 19/12/2025

Area: CHP

Equipment	Job
CC 55	Hot joint machine supply provided after laying the cable and lighting provided
Coal complex	Rooms cleaning was done
CC 201 to 206	Motor greasing done
Street lighting	Cable problems rectified and improved lighting
SCR 5	LT motor 5 provided ,alignment done and trail taken
CC 32,SCR 5	PPM was done
LC 15 to LC 16	2nd line prophibus cable laying under progress