



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED

VISAKHAPATNAM STEEL PLANT

RAW MATERIAL HANDLING PLANT

ELECTRICAL SHIFT REPORT

Date: 26/10/2025

Incharge(s): Lal Singh

Shift: B

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	WBOR ON CO-6A	BC NOT RUNNING ... BS ACTED DUE TO OFF CENTERING	RESET	16:10:00	16:25:00	
2	OHP	CO-58	MPCB TRIPPED	MADE ON	18:10:00	18:20:00	
3	OHP	TBS ON CO-7A	ACB TRIPPED AND BC NOT RUNNING	ACB MADE ON ... BC JAMMING ... INFORMED OPERATION	20:00:00	20:15:00	
4	OHP	TT-2 AND TT-3ON CO-22	SENSOR PROBLEM	BYPASSED	19:00:00	19:15:00	
5	CHP	CC-51	MPD TRIP 20 TIMES	RESET DONE	14:30:00	21:30:00	
6	CHP	CC-51	TRIPPED ON OLR	RESET DONE	14:40:00 16:50:00	14:45:00 16:55:00	
7	CHP	CC 37 SCR-7	MOTORS TRIPPED DUE TO TRACK JAMMING	RESET AND INFORMED FOR CLEANING	19:15:00	19:25:00	
8	CHP	CC-112 SCR-8	BC TRIPPED ON OLR	RESET DONE	20:37:00	20:45:00	
9	CHP	CC-35 SCR-3	LT NOT WORKING MOTOR TRIPPED	RESET DONE	21:30:00	21:40:00	
10	CHP	CC-54	TRIPPED 14 TIMES	RESET DONE	15:30:00	21:45:00	
11	WT	AF-2A	DRIVE TRIPPED	RESET DONE	21:20:00	21:25:00	