



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL GENERAL SHIFT REPORT

Date: 09/02/2026

Area: OHP

Equipment	Job
wobr-4 on co-6a	ppm is done.
co-11a	pullchord and bss switch were replaced and restored in circuit. gallery lighting is improved.
lbds-4 io rack	space power source cable from lbds-4 to 1-14lbds1 is traced, will be used as alternate supply for RIO at 1-1lbds4.
co-26	motor changing job is under progress.