



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 07/08/2025

Incharge(s): Lal Singh, Arnab Roy

Shift: A

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	RSCO-1A	ZSS problem	cage loose , fixed properly	12:20:00	12:45:00	
2	OHP	CO 35	OLR acted	reset done	11:35:00	11:40:00	
3	OHP	CO 26	OLR acted	reset done	09:25:00 10:50:00	09:35:00 10:55:00	
4	OHP	CO 113	MPCB tripped due to jamming	made on , Em stop stuck , bypassed	06:35:00 07:50:00 10:35:00	06:45:00 08:20:00 10:45:00	em stop changed and kept in circuit by G shift
5	OHP	TT 3 on CO 21	signal missing	bypassed	07:30:00	07:40:00	kept in circuit after rectification
6	OHP	BPC 1	OLR acted	reset done	08:45:00	09:00:00	
7	OHP	WOBR on CO 6A and BRC on CO 34	stopping on charge pressure	no electrical problem , informed to mech and opn	08:45:00	10:00:00	
8	CHP	CC 54	Tripped on overload (6 times) due to deck sheet jamming	reset done	09:35:00	11:25:00	
9	CHP	CC 114	OLR acted	reset done	07:25:00	07:30:00	
10	CHP	CC 24	ZSS probe joint problem	re joint done	10:30:00	10:40:00	
11	CHP	CC 50	ZSS cage problem	cage replaced and zss kept in circuit	10:00:00	10:15:00	



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 07/08/2025

Shift: A

Incharge(s): Lal Singh, Arnab Roy

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
12	WT	SCO 1A	Carriage drive tripped on overload	reset done	07:15:00 09:05:00	07:30:00 09:10:00	