



वी.एस.पी  
VSP

**RASTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL GENERAL SHIFT REPORT**

Date: 09/05/2025

Area: OHP

Equipment	Job
LOSP-1	Air compressor checking done
CO-44	TIS PPM done
CO-53,56,57	Lighting circuit rectification done
Ground hopper	Bunkers area lighting done and hoist maintenance done
CO-17	Motor and panel PPM done
BRC-4 on CO-8A	B/C reverse side contactor changing done and tested okay
7.5kw motor	Overhauling is under process
BRC-5 on CO-33M	Skew adjustment done while LT done towards transfer car side
BRC-2 ON Reapir Bay	TWO(7.5KW) LT motors removed and shifted to HVMCC for overhauling. Cables removed through festoon
BRC-1 ON CO-32	BW zss cable checking done. Cable found faulty.To be replaced