



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 01/09/2025

Shift: A

Incharge(s): V Balaji Naik

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	BRC on CO34	Pump not running found Oil level low informed to mechanical and operation	Informed to operation	07:15:00	07:30:00	
2	OHP	BRC on CO31	LT not working found M4 olr acted	Reset done	08:00:00	08:15:00	
3	OHP	CO29	BRS not getting reset	Mis alignment for transmitter and receiver properly fixed	08:15:00	08:30:00	
4	OHP	TT2	PCRD cable soark observed at CO7A area	R phase insulation cut and touching body insulation provided	09:00:00	09:15:00	
5	OHP	Stacker on CO22	RBC contact core sound observed	Informed to G shift (No delay)	12:00:00	12:15:00	
6	OHP	CO66	olr acted	Reset done	08:45:00	09:00:00	
7	OHP	Co67	olr acted	Reset done	08:45:00	09:00:00	
8	CHP	Cc113	Stopped on ZSS due to belt slow down	Informed to operation after cleaning	07:25:00	10:20:00	12.10pm to 01.10pm
9	CHP	SCR6 on CC38	low voltage found Dry type transformer secondary y phase open	Lugging done then ok	08:00:00	10:20:00	
10	CHP	SCR8 on Cc112	luffing lower limit bypassed as per operation request	by passed	11:00:00	11:10:00	
11	CHP	SCR5 on CC32	Lt not working PCRD OT acted	OT limit released then ok	12:50:00	13:00:00	
12	CHP	SCR4 on Cc31	Luffing not working found down limit acted	Limit released	13:00:00	13:10:00	
13	WT	OT4	D1 tripped on PGF fault	Reset done	09:00:00	09:05:00	



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 01/09/2025

Incharge(s): V Balaji Naik

Shift: A

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
14	WT	OT4	D2 pgf fault trip	Reset done	09:25:00	09:29:00	
15	WT	CC3	Carriage drive olr trip due to jam	Reset done	10:32:00	10:45:00	
16	WT	CC2 belt	olr acted 2 times	Reset done	11:20:00	11:25:00	11.45am to 11.49am