



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL GENERAL SHIFT REPORT

Date: 17/10/2025

Area: CHP

Equipment	Job
CC-56	panel and motor ppm done
CC-51/CC-113	Tunnel tail end area sump made on for dewatering
LC-18,CM-17,CM-18	Remote I/O PLC redundancy established with OFC and temporary profibus cables disconnected
SCR-1	Upper MCC room roof sheet welding done and lower MCC room roof old sheets removed and new sheets fixing is under progress
CC-35	Drive end chute sensor checked and kept in circuit
CC-104 BRS	checked and kept in circuit
CC-201,202,203,39,STK-1	ppm work done