



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 24/11/2025

Shift: B

Incharge(s): Nagendra Midde, M Srinivas

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	CO 67	OLR ACTED	RESET	20:10:00	20:20:00	
2	OHP	BRC ON CO 30 LT	CONTROL MCB TRIPPED IN DRIVE PANEL	MADE IT ON	19:20:00	19:35:00	
3	OHP	BRC OM CO 30 B/C	ZSS INTERLOCK PROBE CABLE CUT	REJOINT DONE	19:50:00	20:10:00	
4	CHP	CC 54	OLR ACTED	RESET	15:30:00	21:50:00	20 TIMES
5	CHP	CC 51	FEDING CONV OLR ACTED	RESET	16:45:00	18:30:00	3 TIMES
6	CHP	CC 131	OLR ACTED	RESET	20:20:00 21:30:00	20:25:00 21:35:00	
7	CHP	CC 114	OLR ACTED	RESET	20:55:00	21:00:00	
8	CHP	R1 ON CC 32 LT	M4 TRIPPED	RESET	15:35:00	15:50:00	
9	CHP	CC 201	OLR ACTED	RESET	16:55:00	17:10:00	
10	CHP	S3 ON CC 112 SLEW	SLEW LIMIT ACTED	RELEASED	17:30:00	17:45:00	
11	CHP	SCR 2 ON CC 39 LT	PCRD O/T ACTED	RELEASED	19:50:00	20:05:00	
12	CHP	CC 28	OLR ACTED	RESET	20:35:00	20:40:00	
13	IOSA	OC25A	OM4 ACB TRIPPED	MADE IT ON	21:45:00	22:05:00	