



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 29/12/2025

Shift: C

Incharge(s): Nagendra Midde

| Sl No | Area | Equipment | Problem | Action | From | To | Remarks |
|-------|------|----------------------|----------------------------|------------------|----------|----------|---------|
| 1 | OHP | CO9 | OLR ACTED | RESET | 23:45:00 | 23:55:00 | |
| 2 | OHP | CO25 | OLR ACTED | RESET | 02:45:00 | 02:55:00 | |
| 3 | OHP | WBR ON CO 25 | SLEW DRIVE TRIPPED | RESET | 04:30:00 | 04:45:00 | |
| 4 | CHP | CC 51 | FEEDING CONVEYOR OLR ACTED | RESET | 23:30:00 | 02:10:00 | 6 TIMES |
| 5 | CHP | CC 131 | OLR ACTED | RESET | 03:50:00 | 03:55:00 | |
| 6 | CHP | CC117 | OLR ACTED | RESET | 00:15:00 | 00:30:00 | |
| 7 | CHP | CC 28 T/T F/G | OLR ACTED | RESET | 02:30:00 | 02:40:00 | |
| 8 | CHP | CC 28 | OLR ACTED | RESET | 05:45:00 | 05:55:00 | |
| 9 | CHP | CC 39 | OLR ACTED | RESET | 00:45:00 | 00:50:00 | |
| 10 | CHP | SCR 6 ON CC 39 | B/C OLR ACTED | RESET | 01:45:00 | 01:55:00 | |
| 11 | CHP | SCR 6 ON CC 39 LT | DRIVE TRIPPED | RESET | 02:00:00 | 02:05:00 | |
| 12 | CHP | SCR 5 ON CC 32 | B/C OLR ACTED | RESET | 02:15:00 | 02:30:00 | |
| 13 | CHP | SCR 7 ON 37 B/C | BELT SLIPPING | INFORMED TO OPRN | 04:30:00 | 04:40:00 | |
| 14 | WT | AF5 | DRIVE TRIPPED | RESET | 23:30:00 | 23:35:00 | |