



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 19/09/2025

Incharge(s): V Balaji Naik, Arnab Roy

Shift: B

| Sl No | Area | Equipment    | Problem   | Action   | From                 | To                   | Remarks  |
|-------|------|--------------|---|--|----------------------|----------------------|--|
| 1     | OHP  | WOBr on CO26 | slew not working found drive tripped 2 times  | Reset done   | 15:35:00<br>21:35:00 | 15:45:00<br>21:45:00 |  |
| 2     | OHP  | CO87         | complaint not healthy found PC operated   | Informed to operation to get released                    | 16:30:00             | 16:55:00             |  |
| 3     | OHP  | WOBR on CO26 | Inter locking ZSS cage struck   | ZSS cage changed with new one                            | 15:30:00             | 15:45:00             |  |
| 4     | OHP  | CO27         | OLR acted   | Reset done   | 15:00:00             | 15:10:00             |  |
| 5     | CHP  | CC 26A       | TT no power bcz of old joint insulation failure   | MCCB tripped , insulation provided                       | 15:15:00             | 15:30:00             |  |
| 6     | CHP  | CC 44        | motor MPD trips   | reset  | 17:30:00             | 17:40:00             |  |
| 7     | CHP  | cc 108       | motor MPD trips   | reset  | 18:55:00             | 19:00:00             |  |
| 8     | CHP  | CC 39 SCR 3  | b/c not running,LT motor 7 mpcb trips   | reset  | 20:00:00             | 20:10:00             |  |
| 9     | CHP  | S1 on Cc40   | all drives not working two HT fuses blown out, Drive replaced and connections and parameters entered by ETL | Given for clearance                                      | 16:10:00<br>19:40:00 | 22:30:00<br>22:30:00 | LT rev not holding given control wires direct from interfacing relay to drive self FWD is ok may check |
| 10    | CHP  | SCR3 on CC39 | * BCnot running signal missing found signal healthy. LT not working M7 MPCB tripped                         | * found healthy *M7 motor connection removed and then ok | 20:00:00             | 20:10:00             |  |
| 11    | WT   | Ot1          | drive 1 trips in pgf 1 fault  | reset  | 16:05:00             | 16:10:00             |  |