



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED

VISAKHAPATNAM STEEL PLANT

RAW MATERIAL HANDLING PLANT

ELECTRICAL SHIFT REPORT

Date: 20/01/2026

Shift: A

Incharge(s): K SANKARA RAO

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	brc on co-33m	B/C TRIP ON OLR DUE TO MATERIAL JAMMING	RESET DONE OPERATION REQUIREMENT B/C DIRECTION CHANGED AFTER CLEAR THE MATERIAL CHANGE ORIGINAL DIRECTION NO ELECTRICAL DELAY	08:40:00	09:30:00	
2	OHP	1-141LC-3	REPORTED ALL CONVEYORS RED CHECKED AND FOUND 1-141LC-3 I/C-2 TRIP DUE TO EARTH FAULT	EARTH FAULT ISOLATED THAN I/C-2 CHARGED OK	09:00:00	09:15:00	
3	OHP	TT-4	PCRD CABLE INSULATION FAIL	PROPER TAPPING WAS DONE THAN CLEARANCE GIVEN	09:15:00	09:25:00	
4	OHP	TBS ON CO-19	RIGHT LUFF NOT TAKING PLACE FOUND CONTROL MCB OFF CONDITION	MCB MADE ON THAN OK	09:30:00	09:45:00	
5	OHP	TBS ON CO-7A	RIGHT LUFF NOT WORKING NO PROBLEM	WRONG COMPLAINT	09:20:00	09:30:00	
6	CHP	CC-51	FEEDING CONVEYOR MPD TRIP (3TIMES)	RESET DONE	10:40:00	12:25:00	
7	CHP	CC-51	TRIPPED ON OLR	RESET DONE	12:25:00	12:30:00	
8	CHP	CC-54	OLR ACTED	RESET DONE	11:55:00	12:00:00	
9	CHP	CC-107	OLR ACTED	RESET DONE	08:30:00	08:40:00	