



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED

VISAKHAPATNAM STEEL PLANT

RAW MATERIAL HANDLING PLANT

ELECTRICAL SHIFT REPORT

Date: 26/08/2025

Incharge(s): Lal Singh

Shift: B

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	CO-34	TRIPPED ON OLR	RESET DONE	19:10:00	19:15:00	
2	OHP	CO-32 BRC	CT NOT WORKING ... LIMIT STUCK	MADE FREE... GREASING DONE	19:15:00	19:40:00	
3	OHP	CO-29	TRIPPED ON OLR	RESET DONE	20:20:00	20:30:00	
4	CHP	CC-40 SCR-3	LT NOT WORKING	DUE TO TRACK JAMMING ... INFORMED OPERATION	15:00:00	15:10:00	
5	CHP	CC-112 SCR-8	BC NOT STARTING	DISCHARGE CHUT SENSOR ACTED DUE TO JAMMING ... INFORMED OPERATION	15:20:00	15:30:00	
6	CHP	CC-105 SCR-10	LT NOT WORKING ... M2 TRIPPING	MOTOR DISCONNECTED ...TESTED	15:40:00	15:55:00	
7	CHP	CC-39 SCR-7	LT NOT WORKING	DRIVE TRIPPED ON OL ... RESET DONE	17:50:00	18:00:00	
8	CHP	CC-105 SCR-10	BC NOT RUNNING	MPD TRIPP ... RESET DONE	18:30:00	18:40:00	
9	CHP	CC-28 TT	CHUT SENSOR ACTED	PROB AND MODULE CLEANING DONE THEN RESET	17:00:00	17:20:00	
10	CHP	CC-17, CC-19	BRS KEPT IN CKT	DONE	18:00:00	18:10:00	
11	CHP	CC-53 TT POSITION	CABLE AND SENSOR PROBLEM	BYPASSED IN IO RACK	18:00:00	18:20:00	
12	WT	op-10	MOTORS TRIPPING	CHECKING GOING ON	21:45:00	22:00:00	INFORMED TO C SHIFT