



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 24/12/2025

Shift: C

Incharge(s): Nagendra Midde

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	CC 51	FEEDING CONV OLR ACTED	RESET	23:00:00	01:00:00	3 TIMES
2	OHP	CO 25	OLR ACTED	RESET	03:25:00	03:35:00	
3	CHP	CC 114	OLR ACTED	RESET	05:35:00	05:40:00	
4	CHP	CC 54	OLR ACTED	RESET	22:45:00	22:55:00	
5	CHP	SCR 9 ON CC 104 SLEW	MCCB TRIP	MADE IT ON	23:10:00	23:30:00	
6	CHP	SCR 8 ON CC 112 LT	M8 TRIP	MADE IT ON	23:40:00	23:55:00	
7	CHP	R1 ON CC 33	LUFF MPCB TRIP	MADE IT ON	03:30:00	03:40:00	
8	CHP	R1 ON CC 33 BC	FLUID COUPLING OIL LEAKED	INFORMED TO MECH	02:30:00	02:45:00	
9	CHP	CC 48 ZSS ACTING	BELT NOT MOVING DUE TO JAMMING	INFORMED TO OPERATION	03:20:00	03:40:00	
10	WT	OT1	DRIVE 1 TRIPPED ON PGF1 FAULT	RESET	04:15:00	04:20:00	